

**MINUTES
PLANNING COMMITTEE**

Wednesday 12 October 2022

Councillor John Truscott (Chair)

In Attendance: Councillor Michael Adams Councillor Rosa Keneally
 Councillor Peter Barnes Councillor Meredith Lawrence
 Councillor Jim Creamer Councillor Julie Najuk
 Councillor David Ellis Councillor Marje Paling
 Councillor Rachael Ellis Councillor John Parr
 Councillor Andrew Ellwood Councillor Sam Smith
 Councillor Mike Hope Councillor Henry Wheeler

Absent: Councillor Paul Wilkinson, Councillor Chris Barnfather,
 Councillor Ron McCrossen and Councillor Barbara Miller

Officers in M Avery, N Bryan, S Fayaz and C Goodall
Attendance:

21 APOLOGIES FOR ABSENCE AND SUBSTITUTIONS

Apologies for absence were received from Councillors Barnfather, McCrossen, Miller and Wilkinson. Councillors Creamer, Najuk and Sam Smith attended as substitutes.

22 TO APPROVE, AS A CORRECT RECORD, THE MINUTES OF THE MEETING HELD ON 7 SEPTEMBER 2022

RESOLVED:

That the minutes of the above meeting, having been circulated, be approved as a correct record.

23 DECLARATION OF INTERESTS

The Chair declared collective interests on behalf of all members of the committee on item 4, application number 2022/0240, as the Council owned part of the application site and on item 8, application number 2022/0819, as the Council was the applicant and owned the application site.

Councillor Rachael Ellis declared that she was predetermined on item 8, application number 2022/0819, as she had been involved in lobbying for the CCTV and would therefore not participate in the debate nor vote on the item.

Councillor David Ellis declared on item 8, application number 2022/0819 that as Portfolio Holder he had signed off the application to develop the CCTV and would therefore not participate in the debate nor vote on the item.

24

APPLICATION NO. 2022/0240 - NETHERFIELD METHODIST CHURCH, VICTORIA ROAD. NETHERFIELD

Conversion of existing church property, with subsequent change of use, from community centre (Class F2 - former class D2) to 13 one-bed residential dwelling spaces (Class C3) with accompanying internal and external communal spaces, secure bin store, cycle store and parking provisions.

Oliver Cammell of Hockley Developments (The Applicant), spoke in support of the application.

The Head of Development and Place introduced the report. He recommended that planning permission be granted in accordance with the conditions detailed within the report, but with an amendment to include the planning obligation monitoring fee as detailed in the report.

RESOLVED:

To Grant Planning Permission: Subject to the owner entering into planning obligations secured through a s106 agreement with the Borough Council as the Local Planning Authority and the County Council as the Local Highway to secure contributions towards transport, monitoring fee and to secure a local labour agreement; and subject to the conditions listed for the reasons set out in the report.

Conditions

- 1 The development must be begun not later than three years beginning with the date of this permission.
- 2 The development shall be undertaken in accordance with the details as set out within the application form received on the 25th February 2022, the site location plan received on the 25th February 2022, the revised Planning Statement received on the 17th August 2022, the Marketing Information received on the 21st April 2022, the revised site/block plan received 16th June 2022, drawing name: VR-HD-20001-PI Rev B, the revised first floor plan and roof plan received on the 9th August 2022, drawing names: VR-HD-23001-PI Rev B and VR-HD-29001-PL Rev B, the plan received on the 25th February 2022 showing the basement plan, drawing name VR-HD-21001-PL Rev A, the plan received on the 22nd April 2022 showing the proposed ground floor plan,

drawing name: VR-HD-22001-PL Rev A and the revised plan received on the 17th August 2022 showing the revised elevations, drawing name: VR-HD-20101-PL Rev B.

- 3 The development shall be carried out in accordance with the submitted flood risk assessment (titled FLOOD RISK ASSESSMENT; EA's Site Specific Modelled Data; Updated report in response to EA Letter: LT/2022/126926/01-L01, Ark Environmental Consultancy Ltd, dated April 2022) and the following mitigation measure it details:

- Finished floor levels shall be set no lower than 22.66 metres above Ordnance Datum (AOD) (as per section 9.0 of the FRA).

This mitigation measure shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements.

The measure detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

- 4 No part of the development hereby permitted shall be brought into use until a dropped vehicular footway crossing is available for use and constructed in accordance with the Highway Authority specification.
- 5 No part of the development hereby permitted shall be brought into use until the parking, turning and servicing areas are surfaced in a bound material with the parking bays clearly delineated in accordance with drawing name VR-HD-20001-PI Rev B. The parking, turning and servicing areas shall be maintained in the bound material for the life of the development and shall not be used for any purpose other than the parking, turning and loading and unloading of vehicles.
- 6 No part of the development hereby permitted shall be brought into use until the cycle parking layout as indicated on drawing VR-HD-20001-PI Rev B has been provided.
- 7 No part of the development hereby permitted shall be brought into use until the bin store has been constructed and positioned in accordance with drawing number VR-HD-20001-PI Rev B.
- 8 Prior to the occupation of building(s) hereby permitted, details shall be submitted to and approved in writing by the Local Planning Authority as to the position within the development of at least two (2) Electric Vehicle Recharging Points. The Electric Vehicle Recharging Points shall be in a prominent position on the site and shall be for the exclusive use of zero emission vehicles. The Electric Vehicle Recharging Points shall be installed prior to

occupation of any part of the development and shall be thereafter maintained in the location as approved for the lifetime of the development. All EV charging points shall meet relevant safety and accessibility requirements and be clearly marked with their purpose; which should be drawn to the attention of residents.

- 9 Prior to the commencement of development, a scheme of landscaping showing the location, species and size of specimens to be planted and those to be retained shall be submitted to and approved in writing by the Local Planning Authority. The scheme as approved shall be carried out in the first planting season following the completion of each development phase. Any trees, shrubs or plants that die within a period of five years from the completion of each development phase, or are removed and/or become seriously damaged or diseased in that period, shall be replaced (and if necessary continue to be replaced) in the first available planting season with others of similar size and species.

Reasons

- 1 In order to comply with Section 51 of the Planning and Compulsory Purchase Act 2004.
- 2 For the avoidance of doubt.
- 3 To ensure that the site is safe and suitable for use, thereby taking into consideration the aims of the National Planning Policy Framework 2021, policy 1 of the Aligned Core Strategy 2014 and policy LPD3 of the Local Planning Document 2018.
- 4 In the interests of highway safety and to comply with policy LPD61.
- 5 To ensure that adequate off-street parking provision is made to reduce the possibilities of the proposed development leading to on-street parking in the area and to comply with policy.
- 6 To ensure the cycle parking areas are available for use and to encourage alternative modes of transport to the private motor technical and to comply with guidance contained in the NPPF.
- 7 To enable the bins to be collected by the refuse team on collection day and reduce the likelihood of vehicles blocking the public highway and to comply with policy LPD61.
- 8 To ensure the development is constructed in an appropriate sustainable manner which takes into consideration air quality with in the Borough, and takes into consideration the National Planning Policy Framework, ACS 1 and policy LPD11 of the Councils Local Plan.

- 9 To ensure the character of the area is respected and to comply with policy ASC10.

Notes to Applicant

The developer is encouraged to consider upgrading the EV charging facilities to incorporate mode 3 charging capability as this will help future proof the development and improve its sustainability. A suitable electrical socket can be provided to allow 'Mode 3' charging of an electric vehicle, allowing Smart charging of electric vehicles. All electrical circuits/installations shall comply with the electrical requirements of BS7671:2008 as well as conform to the IET code of practice on Electrical Vehicle Charging Equipment installation.

The applicant is advised that all planning permissions granted on or after 16th October 2015 may be subject to the Community Infrastructure Levy (CIL). Full details of CIL are available on the Council's website. The proposed development has been assessed and it is the Council's view that CIL is not payable on the development hereby approved as the development type proposed is zero rated in this location.

The development makes it necessary to construct a vehicular crossings over a footway of the public highway. These works shall be constructed to the satisfaction of the Highway Authority. Works will be subject to a design check and site inspection for which a fee will apply. The application process can be found at: <http://www.nottinghamshire.gov.uk/transport/licences-permits/temporary-activities>.

Date Recommended: 17th Aug

25 APPLICATION NO. 2014/0273 - LAND AT CORNER OF LONGDALE LANE AND KIGHILL LANE, RAVENSHEAD

Outline Planning Permission for up to 31 No. dwellings with all matters reserved.

The Head of Development and Place introduced the report and provided an update in relation to First Homes as stated at the end of paragraph 4.7 of the officer report. The committee were advised that a report proposing an Interim Planning Policy Statement was approved by Cabinet on 06 October, setting out our local approach, which was permitted by the Planning Practice Guidance and detailed in the officer report.

He concluded that he recommended permission should be granted in accordance with the report but with the addition of a Section 106 monitoring fee.

RESOLVED:

To GRANT OUTLINE PLANNING PERMISSION, subject to the applicant entering into planning obligations with the Borough Council as local planning authority and with the County Council as local highway and education authority for the provision of, or financial contributions towards, Affordable Housing, Transport Infrastructure Improvements, Open Space, Healthcare Facilities, Management Company, Local Labour Agreement and Educational Facilities; Monitoring Fee and subject to the following conditions:

Conditions

- 1 Approval of the details of Access, Appearance, Landscaping, Layout and Scale (hereinafter called "the reserved matters") shall be obtained from the Local Planning Authority before the commencement of any phase of the development.
- 2 Application for the approval of reserved matters must be made not later than three years from the date of the outline permission and the development to which this permission relates must be begun within two years from the date of final approval of reserved matters.
- 3 No phase of development shall commence until a Phasing Schedule has been submitted and approved in writing by the Local Planning Authority. The development hereby approved shall be carried out in phases in accordance with the approved Phasing Schedule
- 4 The detailed plans and particulars to be submitted as reserved matters in relation to scale shall include details of existing and proposed site levels in relation to adjacent properties. The development shall be implemented strictly in accordance with the approved details.
- 5 No development shall commence within any phase unless or until a detailed design of the access to serve that phase has been submitted to and approved in writing by the local planning authority. The development shall be undertaken
- 6 No part of the development hereby permitted, within a phase, shall be brought into use until the visibility splays of 2.4m x 47m, serving that phase, are provided in accordance with details to be first submitted and approved in writing by the Local Planning Authority. The area within the visibility splays referred to in this Condition shall thereafter be kept free of all obstructions, structures or erections exceeding 0.6metres in height.

- 7 No part of the development hereby permitted, within a phase of development, shall be brought into use until a 2.00m wide footway has been provided across the site frontage, within that phase of development, on Longdale Lane, in accordance with details to be first submitted and approved in writing by the Local Planning Authority.
- 8 The formal written approval of the Local Planning Authority is required prior to commencement of any development, within a phase of development, in the site curtilage with regard to parking and turning facilities, access widths, gradients, surfacing, street lighting, structures, visibility splays and drainage (hereinafter referred to as reserved matters.) The development shall be undertaken in accordance with the approved details.
- 9 Details of measures to prevent the deposit of debris upon the adjacent public highway shall be submitted and approved in writing by the Local Planning Authority prior to any works commencing within a phase of development on site. The approved measures shall be implemented prior to any other works commencing on the phase of development.
- 10 No part of the development hereby permitted, within a phase of development, shall be occupied until a Travel Plan has been submitted to and approved in writing by the local planning authority. The Travel Plan shall set out proposals (including targets, a timetable and enforcement mechanism) to promote travel by sustainable modes which are acceptable to the local planning authority and shall include arrangements for monitoring of progress of the proposals. The Travel Plan shall be implemented strictly in accordance with the timetable set out in that plan.
- 11 A plan showing satisfactory arrangements for refuse collection shall be submitted with the 'layout' reserved matter.
- 12 No development shall take place, within a phase of development, until a Construction Environmental Method Statement has been submitted to, and approved in writing by, the local planning authority. The approved Statement shall be adhered to throughout the construction period. The Statement shall provide for: (i) the parking of vehicles of site operatives and visitors; (ii) loading and unloading of plant and materials; (iii) storage of plant and materials used in constructing the development; (iv) the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate; (v) wheel washing facilities; (vi) measures to control the emission of dust and dirt during construction; (vii) a scheme for recycling/disposing of waste resulting from construction works.

- 13 Before development is commenced, within a phase of development, there shall be submitted to and approved in writing by the Local Planning Authority details of a surface water drainage scheme for that phase based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed and shall be retained for the lifetime of the development. The scheme to be submitted shall demonstrate: (1) The utilisation of holding sustainable drainage techniques which incorporate at least two differing forms of SuDS treatment in accordance with Table 3.3 of CIRIA C697 'The SuDS Manual' prior to discharging from the site; (2) The limitation of surface water run-off to the equivalent Greenfield runoff rate; (3) The ability to accommodate surface water run-off on-site up to the critical 1 in 100 year event plus an appropriate allowance for climate change, based upon the submission of drainage calculations; and (4) Responsibility for the future maintenance of drainage features.
- 14 Before development is commenced, within a phase of development, there shall be submitted into and approved in writing by the Local Planning Authority an Arboricultural Impact Assessment and Mitigation Strategy. The mitigation strategy shall include (1) A tree protection plan to graphically show the locations of any tree and root protection barriers; (2) Arboricultural impact assessment identifying what impacts might arise from the proposed works; (3) Arboricultural Method Statement to give guidance on aspects of proposed works which were identified within the Arboricultural impact assessment which provides guidance as to how works might be mitigated or compensated for; (4) Details of any special engineering works and surfacing required near trees. The approved measures of protection shall be implemented strictly in accordance with the approved details for the duration of the construction period.
- 15 No external artificial lighting shall be provided, within a phase of development, until there has been submitted to and approved in writing by the Borough Council details of a 'bat friendly' lighting scheme to ensure that artificial lighting (including any construction site lighting and compound lighting), avoids illuminating boundary features such as hedgerows and other areas of retained or created habitat. The scheme shall be implemented strictly in accordance with the approved details.
- 16 The detailed plans and particulars to be submitted as reserved matters in relation to ecology shall include a Phase 1: Habitat Survey and Ecological Assessment in relation to each phase of

development. Detail shall include a survey for reptiles on field margins. In particular the assessment shall include precise details of any mitigation measures required and measures of how any reptiles would be cleared sensitively prior to development. The mitigation measures shall be implemented strictly in accordance with the approved details before the development is first commenced.

- 17 The detailed plans and particulars to be submitted as reserved matters in relation to appearance shall include details of the materials to be used in the external elevations and roofs of the proposed buildings. The development shall be carried out strictly in accordance with the approved details, which shall be retained for the lifetime of the development.
- 18 The detailed plans and particulars to be submitted as reserved matters in relation to landscaping shall include: (a) details of the size, species, positions and density of all trees and shrubs to be planted, which shall consist of native species, ideally of local provenance, where possible; (b) details of any mitigation measures, compensatory habitat, or wildlife corridors; (c) details of the boundary treatments, including those to individual plot boundaries; (d) the proposed means of surfacing access roads, car parking areas, roadways and the frontages of properties such as driveways and footpaths to front doors and (e) a programme of implementation. The development shall be implemented in accordance with the approved details.
- 19 If within a period of five years beginning with the date of the planting of any tree or shrub, approved as reserved matters in relation to landscaping, that tree or shrub, or any tree or shrub that is planted in replacement of it, is removed, uprooted or destroyed or dies, or becomes in the opinion of the Borough Council seriously damaged or defective, another tree or shrub of the same species and size as that originally planted shall be planted at the same place.
- 20 Development must not commence, within a phase of development, until the following has been complied with: Site Characterisation: An assessment of the nature and extent of any potential contamination has been submitted to and approved in writing by the Local Planning Authority. This assessment must be undertaken by a competent person, and shall assess any contamination on the site, whether or not it originates on the site. Moreover, it must include; a survey of the extent, scale and nature of contamination and; and assessment of the potential risks to: human health, property, adjoining land, controlled waters, ecological systems, archaeological sites and ancient monuments. Submission of Remediation Scheme: Where required, a detailed remediation scheme (to bring the condition suitable for the

intended use by removing unacceptable risks to critical receptors) should be submitted to and approved in writing by the Local Planning Authority. The scheme must include all works to be undertaken, proposed remediation objectives and remediation criteria, an appraisal of remedial options, and proposal of the preferred option(s), and a timetable of works and site management procedures.

- 21 In the event that remediation is required to render the development suitable for use, the agreed remediation scheme shall be implemented in accordance with the approved timetable of works. Prior to occupation of any building(s) a Verification Report (That demonstrates the effectiveness of the remediation carried out) must be submitted and approved in writing by the Local Planning Authority.
- 22 In the event that contamination is found at any time when carrying out the approved development that was not previously identified it must be reported in writing immediately to the Local Planning Authority and once the Local Planning Authority has identified the part of the site affected by the unexpected contamination development must be halted on that part of the site. An Assessment must be undertaken in accordance with the requirements above, and where remediation is necessary a remediation scheme, together with a timetable for its implementation and verification reporting, must be submitted to and approved in writing by the Local Planning Authority.
- 23 From the date of first occupation every property built on the site with one or more dedicated vehicle parking spaces and/ or a garage shall be provided with access to an electric vehicle (EV) charge point. Charge points must have a minimum power rating output of 7kW on a dedicated circuit, capable of providing a safe overnight charge to an electric vehicle.

All EV charging points shall meet relevant safety and accessibility requirements and be clearly marked with their purpose; which should be drawn to the attention of new residents in their new home welcome pack / travel planning advice.

Reasons

- 1 To comply with the requirements of Section 92 of the Town and Country Planning Act 1990. The application is expressed to be in outline only in accordance with Article 5 of the Town and Country Planning (Development Management Procedure)(England) Order 2015.

- 2 To comply with the requirements of Section 92 of the Town and Country Planning Act 1990.
3. To enable the site to be developed in a phased manner
- 4 To ensure a satisfactory development in accordance with the aims of Policy 10 of the Aligned Core Strategy for Gedling Borough (September 2014
- 5 In the interest of highway safety.
- 6 To ensure an adequate form of development in the interests of highway safety in accordance with Policy LPD35.
- 7 To ensure an adequate form of development in the interests of highway safety in accordance with Policy LPD35.
- 8 To ensure an adequate form of development in the interests of highway safety in accordance with Policy LPD35.
- 9 In the interest of Highway Safety.
- 10 To ensure an adequate form of development in the interests of highway safety in accordance with Policy LPD35.
- 11 To ensure an adequate form of development in the interests of highway safety in accordance with Policy LPD35.
- 12 To protect the residential amenity of the area in accordance with the aims of Section 11 of the National Planning Policy Framework and Policy 10 of the Aligned Core Strategy for Gedling Borough (September 2014).
- 13 To prevent the increased risk of flooding; to improve and protect water quality; to improve habitat and amenity; to ensure the future maintenance of the sustainable drainage structures; and to protect the water environment from pollution, in accordance with the National Planning Policy Framework and Policies 1 and 17 of the Aligned Core Strategy Submission Documents.
- 14 To minimise any potential impacts on biodiversity and the landscape in accordance with Section 11 of the National Planning Policy Framework, Policy 17 of the Aligned Core Strategy for Gedling Borough (September 2014), and LPD18.
- 15 To minimise any potential impacts on biodiversity in accordance with Section 11 of the National Planning Policy Framework and Policy 17 of the Aligned Core Strategy for Gedling (September 2014).

- 16 To minimise any potential impacts on biodiversity in accordance with Section 11 of the National Planning Policy Framework, Policy 17 of the Aligned Core Strategy for Gedling (September 2014), and LPD18.
- 17 To ensure a satisfactory development in accordance with the aims of Policy 10 of the Aligned Core Strategy for Gedling Borough (September 2014) and Policy ENV1 of the Gedling Borough Replacement Local Plan (Certain Policies Saved 2014).
- 18 To ensure that the landscaping of the proposed development accords with Policy 10 of the Aligned Core Strategy for Gedling Borough (September 2014)
- 19 To ensure a satisfactory development, in accordance with Policy 10 of the Aligned Core Strategy for Gedling Borough
- 20 To ensure that practicable and effective measures are taken to treat, contain or control any contamination and to protect controlled waters in accordance with the aims of LPD7.
- 21 To ensure that practicable and effective measures are taken to treat, contain or control any contamination and to protect controlled waters in accordance with the aims of LPD7.
- 22 To ensure that practicable and effective measures are taken to treat, contain or control any contamination and to protect controlled waters in accordance with the aims of LPD7.
- 23 In the interest of sustainable travel

Notes to Applicant

The applicant should note that notwithstanding any planning permission that if any highway forming part of the development is to be adopted by the Highways Authority. The new roads and any highway drainage will be required to comply with the Nottinghamshire County Council's current highway design guidance and specification for roadworks.

It is strongly recommended that the developer contact the Highway Authority at an early stage to clarify the codes etc. with which compliance will be required in the particular circumstance, and it is essential that design calculations and detailed construction drawings for the proposed works are submitted to and approved by the County Council (or District Council) in writing before any work commences on site.

In order to carry out the off-site works required you will be undertaking work in the public highway which is land subject to the provisions of the Highways Act 1980 (as amended) and therefore land over which you have no control. In order to undertake the works you will need to enter into an agreement under Section 278 of the Act. All correspondence with the Highway Authority should be addressed to: TBH - NCC (Highways Development Control) (Floor 8), Nottinghamshire County Council, County Hall, Loughborough Road, West Bridgford, Nottingham, NG2 7QP.

The Environment Agency advises that surface water run-off should be controlled as near to its source as possible through a sustainable drainage approach to surface water management. Sustainable Drainage Systems (SuDS) are an approach to managing surface water run-off which seeks to mimic natural drainage systems and retain water on-site, as opposed to traditional drainage approaches which involve piping water off-site as quickly as possible.

The applicant is advised that all planning permissions granted on or after 16th October 2015 may be subject to the Community Infrastructure Levy (CIL). Full details of CIL are available on the Council's website. The proposed development has been assessed and it is the Council's view that CIL IS PAYABLE on the development hereby approved. The actual amount of CIL payable will be calculated when a decision is made on the subsequent reserved matters application.

Planning Statement - The Borough Council has worked positively and proactively with the applicant in accordance with paragraph 38 of the National Planning Policy Framework (2021). Negotiations have taken place during the determination of the application to address adverse impacts identified by officers. Amendments have subsequently been made to the proposal, addressing the identified adverse impacts, thereby resulting in a more acceptable scheme and a favourable recommendation.

No removal of hedgerows, trees or shrubs which have the potential to support nesting birds shall take place between 1st March and 31st August inclusive, unless a competent ecologist has undertaken a careful, detailed check for active birds' nests immediately before clearance works commence and provided written confirmation that no birds will be harmed and/or that there are appropriate measures in place to protect nesting bird interest on site. Any such written confirmation should be submitted to the local planning authority. As you will be aware all birds, their nests and eggs (except pest species) are protected by the Wildlife and Countryside Act 1981 (and as amended).

In order to carry out the off-site works required you will be undertaking work in the public highway which is land subject to the provisions of the Highways Act 1980 (as amended) and therefore land over which you have no control. In order to undertake the works you will need to enter

into an agreement under Section 278 of the Act. Please contact the Highway Authority for details.

Advice regarding travel plans can be obtained from the Travel Plans Officer at Nottinghamshire County Council, County Hall, Loughborough Road, West Bridgford, Nottingham.

The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to The Coal Authority on 0845 762 6848. Further information is also available on The Coal Authority website at www.coal.decc.gov.uk. Property specific summary information on past, current and future coal mining activity can be obtained from The Coal Authority's Property Search Service on 0845 762 6848 or at www.groundstability.com.

Informative: The developer is encouraged to consider upgrading the EV charging facilities to incorporate mode 3 charging capability as this will help future proof the development and improve its sustainability. A suitable electrical socket can be provided to allow 'Mode 3' charging of an electric vehicle, allowing Smart charging of electric vehicles.

All electrical circuits/installations shall comply with the electrical requirements of BS7671:2008 as well as conform to the IET code of practice on Electrical Vehicle Charging Equipment installation (2015

Reasons for Decision

The development has been considered in accordance with the National Planning Policy Framework, the Aligned Core Strategy for Gedling Borough (September 2014) The Local Planning Document Part 2 where appropriate. In the opinion of the Borough Council, the proposed development largely accords with the relevant policies of these frameworks and plans. Where the development conflicts with the Development Plan, it is the opinion of the Borough Council that other material considerations indicate that permission should be granted. The benefits of granting the proposal outweigh any adverse impact of departing from the Development Plan.

26

APPLICATION NO. 2022/0584 - LAND AT NORTH WEST PARK ROAD, CALVERTON

Application for the approval of reserved matters (layout, landscaping, scale and appearance) for the erection of 101 dwellings and associated infrastructure, pursuant to outline approval 2018/0607 (re-plan of reserved matters approval 2020/0020, which includes an additional 12 units taking the total number of units to 363).

The Principal Planning Officer introduced the report.

RESOLVED:

To grant reserved matters approval, subject to the imposition of conditions, as set out in the report:

1. This permission shall be read in accordance with the application form and following list of approved drawings:
Calverton-Location Plan (08) 003 Rev C
Planning Layout SS - 1256 - (08) 001 Rev S
Affordable Housing Plan CAL-AHP-001 Rev G
Public Open Space Plan CAL-POSP-001
7403-L-13-21 Planting Plans REV I
CAL-CPR-001 Calverton Charter Plan Replan (1 of 2) Rev E
CAL-CPR-002 Calverton Charter Plan Replan (2 of 2) Rev F
Calverton PROW Plan SS - 1256 - (08) 002 Rev K

House types:

Danbury End DA_MA_End_R21 -901
Danbury Mid DA_MAQ_Mid_R21 -901
Alnwick 638-PL-01
Chatsworth 918-PL-01
Chedworth Bay (side) 1222-PL-04
Chedworth Bay 1222-PL-03
Chedworth Render 1222-PL-02
Chedworth 999-PL-02
Clayton Corner Render 999-PL-01
Corfe Render 1415-PL-02
Corfe 1415-PL-01
Garages STDGD-02
Hanbury 761-PL-01
Hatfield Corner Render 969-PL-04
Hatfield Corner 969-PL-03
Hatfield Render 969-PL-02
Hatfield 969-PL-01
Kendal Render 1190-PL-02
Kendal 1190-PL-01
Lumley Render 1220-PL-02
Lumley 1220-PL-01
Roseberry Render 1096-PL-02
Roseberry 1096-PL-01
Rufford 870-PL-01
Souter Render 951-PL-02
Souter 951-PL-01
Sutton Render 987-PL-02
Sutton 987-PL-01
Winster Render 1275-PL-02
Winster 1275-PL-01

The development shall thereafter be undertaken in accordance with these plans/details.

2. No part of the development hereby permitted shall be brought into use until all drives and parking areas are surfaced in a bound material (not loose gravel). The surfaced drives and parking areas shall then be maintained in such bound material for the life of the development.
3. No part of the development hereby permitted shall be brought into use until the access driveways and parking areas are constructed with provision to prevent the unregulated discharge of surface water from the driveways and parking areas to the public highway. The provision to prevent the unregulated discharge of surface water to the public highway shall then be retained for the life of the development.
4. The landscaping scheme as approved shall be carried out in the first planting season following the completion of the development. Any trees, shrubs or plants that die within a period of five years from the completion of the development, or are removed and/or become seriously damaged or diseased in that period, shall be replaced (and if necessary continue to be replaced) in the first available planting season with others of similar size and species.

Reasons

1. For the avoidance of doubt.
2. To reduce the possibility of deleterious material being deposited on the public highway (loose stones etc) and to comply with policy LPD61.
3. To ensure surface water from the site is not deposited on the public highway causing dangers to road users and to comply with policy LPD61.
4. To ensure that the development assimilate within the green environment and to comply with guidance within the NPPF.

Notes to Applicant

It is an offence under S148 and S151 of the Highways Act 1980 to deposit mud on the public highway and as such you should undertake every effort to prevent it occurring.

The applicant should note that notwithstanding any planning permission, if any highway forming part of the development is to be adopted by the Highways Authority, the new roads and any highway drainage will be

required to comply with the Nottinghamshire County Council's current highway design guidance and specification for roadworks.

The Advanced Payments Code in the Highways Act 1980 applies and under section 219 of the Act payment will be required from the owner of the land fronting a private street on which a new building is to be erected. The developer should contact the Highway Authority with regard to compliance with the Code, or alternatively to the issue of a Section 38 Agreement and bond under the Highways Act 1980. A Section 38 Agreement can take some time to complete. Therefore, it is recommended that the developer contact the Highway Authority as early as possible.

It is strongly recommended that the developer contact the Highway Authority at an early stage to clarify the codes etc. with which compliance will be required in the particular circumstance, and it is essential that design calculations and detailed construction drawings for the proposed works are submitted to and approved by the County Council (or District Council) in writing before any work commences on site.

All correspondence with the Highway Authority should be addressed to:-
Hdc.south@nottscc.gov.uk

The applicant is advised that all planning permissions granted on or after 16th October 2015 may be subject to the Community Infrastructure Levy (CIL). Full details of CIL are available on the Council's website.

The proposed development has been assessed and it is the Council's view that CIL IS PAYABLE on the development hereby approved as is detailed below. Full details about the CIL Charge including, amount and process for payment will be set out in the Regulation 65 Liability Notice which will be sent to you as soon as possible after this decision notice has been issued. If the development hereby approved is for a self-build dwelling, residential extension or residential annex you may be able to apply for relief from CIL. Further details about CIL are available on the Council's website or from the Planning Portal: www.planningportal.gov.uk/planning/applications/howtoapply/whattosubmit/cil

Wheel washing facilities shall be used by any vehicle carrying mud, dirt or other debris on its wheels before leaving the site so that no mud, dirt or other debris is discharged or carried on to a public road.

Please note that in accordance with Schedule 2, Part 1, Class F of the Town and Country Planning (General Permitted Development) (England) Order 2015, there would be a need to ensure that any hard surface over 5m squared would need to be permeable or drained in such a manner so as to ensure surface water drains within the curtilage of the property.

**APPLICATION NO. 2021/1464 - ASHDALE, NOTTINGHAM ROAD,
BURTON JOYCE**

Variation of conditions 3 (approved drawings), 4 (highways) and 18 (trees) of planning permission 2020/0238 (An outline application for 11 new dwellings with matters of access, scale and layout under consideration).

The Principal Planning Officer introduced the report.

RESOLVED:

To GRANT PLANNING PERMISSION subject to the owner entering into planning obligations secured through a s106 agreement with the Borough Council as the Local Planning Authority to secure the long term maintenance of the road and subject to the following conditions for the reasons set out in the report.

Conditions

- 1 Details of appearance and landscaping (hereinafter called the reserved matters) for the development shall be submitted to and approved in writing by the Local Planning Authority before any development begins and the development shall be carried out as approved.
- 2 The application for the approval of reserved matters must be made not later the 11th August 2024 and the development to which this permission relates must be begun within two years from the date of the final approval of reserved matters.
- 3 This permission shall be read in accordance with the application form and following approved drawing: 153/A-NR-BJ/PI-2 Rev D. The development shall thereafter be undertaken in accordance with these plans/details.
- 4 No dwelling hereby approved shall be occupied until a suitable access arrangement has been provided in accordance with the approved drawing no. 153/A-NR-BJ/PI-2 Rev D.
- 5 No dwelling shall be occupied until the roads necessary to serve that dwelling have been constructed to base level.
- 6 No dwelling shall be occupied until all drives and parking areas are surfaced in a bound material (not loose gravel). The surfaced drives and parking areas shall then be maintained in such bound material for the life of the development.

- 7 Prior to the commencement of development details of the existing and proposed ground levels of the site and finished floor levels of the dwellings shall be submitted to and approved in writing by the Local Planning Authority. The development shall thereafter be undertaken in accordance with the approved details.
- 8 No dwelling shall be occupied until one or more dedicated vehicle parking spaces and/ or a garage have been provided with access to an electric vehicle (EV) charge point. Charge points must have a minimum power rating output of 7kW on a dedicated circuit, capable of providing a safe overnight charge to an electric vehicle. All EV charging points shall meet relevant safety and accessibility requirements and be clearly marked with their purpose; which should be drawn to the attention of new residents in their new home welcome pack / travel planning advice.
- 9 Prior to commencement of the development a Construction Emission Management Plan (CEMP) for minimising the emission of dust and other emissions to air during the site preparation and construction shall be submitted to and approved in writing by the Local Planning Authority. The CEMP must be prepared with due regard to the guidance produced by the Council on the assessment of dust from demolition and construction and include a site specific dust risk assessment; all works on site shall, thereafter, be undertaken in accordance with the approved CEMP
- 10 The development shall be carried out in accordance with the submitted flood risk assessment (ref: Land at Ashdale, Nottingham Road, Burton Joyce, Gracemachin Planning and Property Ltd, Farrow Walsh Consulting, FW1907_FRA_001, V2.1, 06/04/2020) and the following mitigation measures it details: Finished floor levels shall be set no lower than 19.82 metres above Ordnance Datum (AOD) as stated within section 7.2.1 of the FRA. The mitigation measures shall then be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.
- 11 No part of the development hereby approved shall commence until a detailed surface water drainage scheme based on the principles set forward by the approved Flood Risk Assessment (FRA) and Drainage Strategy, has been submitted to and approved in writing by the Local Planning Authority in consultation with the Lead Local Flood Authority. The scheme shall be implemented in accordance with the approved details prior to the first occupation of any dwelling. The scheme to be submitted shall:
 - Demonstrate that the development will use SuDS throughout the site as a primary means of surface water management and that design is in accordance with CIRIA C753. -

Limit the discharge rate generated by all rainfall events up to the 100 year plus 40% (for climate change) critical rain storm 5 l/s rates for the developable area. - Provision of surface water run-off attenuation storage in accordance with 'Science Report SCO30219 Rainfall Management for Developments' and the approved FRA - Provide detailed design (plans, network details and calculations) in support of any surface water drainage scheme, including details on any attenuation system, and the outfall arrangements. Calculations should demonstrate the performance of the designed system for a range of return periods and storm durations inclusive of the 1 in 1 year, 1 in 2 year, 1 in 30 year, 1 in 100 year and 1 in 100 year plus climate change return periods. - For all exceedance to be contained within the site boundary without flooding new properties in a 100year+40% storm. - Details of STW approval for connections to existing network and any adoption of site drainage infrastructure. - Evidence of how the on-site surface water drainage systems shall be maintained and managed after completion and for the lifetime of the development.

- 12 Before development is commenced there shall be submitted to and approved in writing by the Local Planning Authority drainage plans for the proposed means of disposal of foul sewage. The scheme shall be implemented in accordance with the approved details before the development is first brought into use and shall be retained for the lifetime of the development thereafter.
- 13 In the event that contamination is found at any time when carrying out the approved development it must be reported in writing immediately to the Local Planning Authority and once the Local Planning Authority has identified the part of the site affected by the unexpected contamination development must be halted on that part of the site. An assessment must be undertaken in accordance with the requirements of the Local Planning Authority, and where remediation is necessary a remediation scheme, together with a timetable for its implementation and verification reporting, must be submitted to and approved in writing by the Local Planning Authority.
- 14 Development shall be undertaken in accordance with the approved noise report, completed by BSP Consulting, BSP Document Ref: RDBJ-BSP-ZZ-XX-RP-C-001-P1_Environmental_Noise_Assessment and the mitigation therein, notably with regard to window details and ventilation to the dwellings and fencing to the garden areas. Verification that the approved sound insulation has been implemented and is fully operational shall be submitted to and be approved in writing by the Local Planning Authority.

- 15 Development shall be undertaken in accordance with the Ecological Appraisal Report by JJH Consulting Ltd dated December 2019 and the recommendations and mitigation measures adhered to at all times.
- 16 Prior to the commencement of development, a further badger survey of the site shall be submitted and approved in writing by the Local Planning Authority. Any mitigation contained in the approved report shall thereafter be implemented.
- 17 Prior to the commencement of development, Great Crested Newt presence/absence surveys shall be submitted and approved in writing by the Local Planning Authority. Any mitigation contained in the approved report shall thereafter be implemented.
- 18 The development shall be undertaken in accordance with the Arboricultural Report submitted as part of this Section 73 application and Impact Assessment by AWA Tree Consultants, dated August 2020, Reference AWA2971 and the Arboricultural Method Statement by AWA Tree Consultants, dated August 2020 reference AWA3363 submitted as part of the outline application, specific attention shall be given to the timings of events from arboricultural works through erection of protective fencing and development to protective fence removal and the need for strict monitoring throughout the process. The protective fencing shall be provided before site preparation commences and the protective fencing shall remain in place at all times during site preparation and development. The protective fencing shall only be removed following completion of the development.
- 19 Prior to the erection of any external lighting (other than within the curtilages of the approved dwellings) there shall be submitted to and approved in writing by the Local Planning Authority details of all such lighting, including levels of illumination and a lux plot of the estimated luminance. The external lighting shall be provided in accordance with the approved details and shall be retained as such thereafter for the lifetime of the development.
- 20 No above ground construction works shall commence until details of bat and bird boxes to be incorporated within the fabric of the buildings and/or within the site have been submitted to and approved in writing by the Local Planning Authority. The bat and bird boxes shall thereafter be provided prior to the first occupation of the development hereby approved.
- 21 No part of the development hereby permitted shall take place until details of the new road have been submitted to and approved in writing by the Local Planning Authority including longitudinal and cross-sectional gradients, visibility splays, street lighting, drainage and outfall proposals, construction specification, provision of and

diversion of utilities services, and any proposed structural works. The development shall be implemented in accordance with the approved details and retained thereafter for the life of the development.

- 22 All access driveways and parking areas shall be constructed with provision to prevent the unregulated discharge of surface water from the driveways and parking areas to the public highway. The provision to prevent the unregulated discharge of surface water to the public highway shall then be retained for the life of the development.
- 23 No development hereby permitted shall commence until details of wheel washing facilities have been submitted to and approved in writing by the Local Planning Authority. The wheel washing facilities thereby approved shall be maintained in working order for the duration of the construction works at all times and shall be used by any vehicle carrying mud, dirt or other debris on its wheels before leaving the site so that no mud, dirt or other debris is discharged or carried on to a public road.

Reasons

- 1 To comply with the provision of Section 92(2) of the Town and Country Planning Act 1990.
- 2 To comply with the requirements of Section 51 of the Planning and Compulsory Purchase Act 2004.
- 3 For the avoidance of doubt.
- 4 To ensure an adequate form of development in the interests of highway safety and to comply with policy LPD61.
- 5 To ensure that each dwelling has appropriate vehicular access and to comply policy LPD61.
- 6 To ensure that loose material does not enter the highway and to comply with policy LPD61.
- 7 This pre-commencement condition is necessary to ensure that the development does not have a detrimental impact upon visual amenity or upon the occupiers of adjacent dwellings.
- 8 To ensure the development is constructed in an appropriate sustainable manner which takes into consideration air quality with in the Borough, and takes into consideration the National Planning Policy Framework and policy LPD11 of the Councils Local Plan.

- 9 To ensure the development is constructed in an appropriate sustainable manner which takes into consideration air quality within the Borough, and takes into consideration the National Planning Policy Framework and policy LPD11 of the Councils Local Plan.
- 10 To ensure that the site is safe and suitable for use, thereby taking into consideration the aims of the National Planning Policy Framework 2021 (NPPF), policy 1 of the Aligned Core Strategy 2014 and policy LPD3 of the Local Planning Document 2018.
- 11 A detailed surface water management plan is required to ensure that the development is in accordance with National Planning Policy Framework 2021 and local planning policies. It should be ensured that all major developments have sufficient surface water management, are not at increased risk of flooding and do not increase flood risk off-site.
- 12 To ensure foul water is adequately disposed of and to comply with policies LPD4, LPD5 and LPD6.
- 13 To ensure the development is safe and suitable for use, thereby taking into consideration paragraph 121 of the National Planning Policy Framework and policy LPD7 of the Councils Local Plan.
- 14 To ensure that amenity of proposed dwellings are suitably protected and to comply with guidance within the NPPF.
- 15 To ensure that protected species are not detrimentally impacted and to comply with guidance within the NPPF.
- 16 To ensure that protected species are not detrimentally impacted and to comply with guidance within the NPPF.
- 17 To ensure that protected species are not detrimentally impacted and to comply with guidance within the NPPF.
- 18 To ensure that the trees to be retained at the site are appropriately protected at all times.
- 19 In the interests of protecting ecological interests.
- 20 No above ground construction works shall commence until details of bat and bird boxes to be incorporated within the fabric of the buildings and/or within the site have been submitted to and approved in writing by the Local Planning Authority. The bat and bird boxes shall thereafter be provided prior to the first occupation of the development hereby approved.

- 21 To ensure the development is constructed to an acceptable standard.
- 22 In the interests of highway safety.
- 23 In the interests of highway safety.

Reasons for Decision

The principle of the development accords with the objectives of national and local planning policies. It is considered that the site could be used for residential development without causing undue harm to visual and residential amenity, highway safety, ecological interests or flooding. It is therefore considered that the granting of outline planning permission would fully accord with the objectives of the relevant planning policies set out in the National Planning Policy Framework, Aligned Core Strategy, Local Planning Document and Supplementary Planning Documents.

Notes to Applicant

It is an offence under S148 and S151 of the Highways Act 1980 to deposit mud on the public highway and as such you should undertake every effort to prevent it occurring. The applicant should note that notwithstanding any planning permission if any highway forming part of the development is to be adopted by the Highways Authority, the new roads and any highway drainage will be required to comply with Nottinghamshire County Council's current highway design guidance and specification for roadworks. The Advanced Payments Code in the Highways Act 1980 applies and under section 219 of the Act payment will be required from the owner of the land fronting a private street on which a new building is to be erected. The developer should contact the Highway Authority with regard to compliance with the Code, or alternatively to the issue of a Section 38 Agreement and bond under the Highways Act 1980. A Section 38 Agreement can take some time to complete. Therefore, it is recommended that the developer contact the Highway Authority as early as possible. It is strongly recommended that the developer contact the Highway Authority at an early stage to clarify the codes etc. with which compliance will be required in the particular circumstance, and it is essential that design calculations and detailed construction drawings for the proposed works are submitted to and approved by the County Council (or District Council) in writing before any work commences on site. All correspondence with the Highway Authority should be addressed to:- NCC (Highways Development Control) (Floor 3) Nottinghamshire County Council County Hall Loughborough Road West Bridgford Nottingham, NG2 7QP

Planning Practice Guidance and section H of the Building Regulations 2010 detail surface water disposal hierarchy. The disposal of surface water by means of soakaways should be considered as the primary

method. If this is not practical and there is no watercourse is available as an alternative other sustainable methods should also be explored. If these are found unsuitable, satisfactory evidence will need to be submitted, before a discharge to the public sewerage system is considered. Severn Trent Water advises that there is a public sewer located within the application site. Public sewers have statutory protection by virtue of the Water Industry Act 1991 as amended by the Water Act 2003 and you may not build close to, directly over or divert a public sewer without consent. You are advised to contact Severn Trent Water to discuss your proposals. Severn Trent Water will seek to assist you in obtaining a solution which protects both the public sewer and the proposed development. They may obtain copies of our current guidance notes and application forms for diversions from either our website (www.stwater.co.uk) or by contacting our Developer Services Team (Tel: 0800 707 6600).

No vegetation clearance or ground works shall take place on site during the bird nesting season (1st March to 31st August inclusive in any given year), unless pre-commencement checks for nesting birds have been undertaken by an appropriately qualified ecologist. If any nesting birds are found to be present, details of any proposed mitigation measures shall be submitted to and approved in writing by the Borough Council before the development commences. The mitigation measures shall be implemented in accordance with the approved details before development commences, unless otherwise prior agreed in writing by the Borough Council.

The applicant is advised that any site clearance works are undertaken outside of the bird breeding season - October to February inclusive.

The applicant is advised that conditions 16 and 17, relating to the requirement for a further badger survey and a survey regarding the potential presence of Great Crested Newts shall be read in conjunction with the submitted Ecological Appraisal Report by JJH Consulting Ltd December 2019.

Planning Statement - The Borough Council has worked positively and proactively with the applicant in accordance with paragraph 38 of the National Planning Policy Framework (2021). Negotiations have taken place during the assessment of the application to address adverse impacts identified by officers. Amendments have subsequently been made to the proposal, addressing the identified adverse impacts, thereby resulting in a more acceptable scheme and a favourable recommendation.

The developer is encouraged to consider upgrading the EV charging facilities to incorporate additional mode 3 charging capability as this will help future proof the development and improve its sustainability. A suitable 'IEC 62196' electrical socket (minimum rated output of 3.7kw /16A) can be provided in addition to the standard 3 pin socket to allow

'Mode 3' charging of an electric vehicle. Mode 3 charging, using a suitable cable and charging point, allows Smart charging of electric vehicles. All electrical circuits/installations shall comply with the electrical requirements of BS7671:2008 as well as conform to the IET code of practice on Electrical Vehicle Charging Equipment installation (2015).

In relation to the lighting condition above the submission of a bat-sensitive lighting scheme, should be developed in accordance with the Bat Conservation Trust publication "Artificial Lighting and Wildlife - Interim Guidance: recommendations to help minimise the impact of artificial lighting" dated June 2014.

The attached permission is for development which will involve building up to, or close to, the boundary of the site. Your attention is drawn to the fact that if you should need access to neighbouring land in another ownership in order to facilitate the construction of the building and its future maintenance you are advised to obtain permission from the owner of the land for such access before beginning your development.

The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to The Coal Authority on 0845 762 6848. Further information is also available on The Coal Authority website at www.coal.decc.gov.uk. Property specific summary information on past, current and future coal mining activity can be obtained from The Coal Authority's Property Search Service on 0845 762 6848 or at www.groundstability.com.

You are advised that planning permission does not override any private legal matters which may affect the application site, over which the Borough Council has no jurisdiction (e.g. covenants imposed by former owners, rights of light, etc.).

The applicant is advised that all planning permissions granted on or after 16th October 2015 may be subject to the Community Infrastructure Levy (CIL). Full details of CIL are available on the Council's website. The proposed development has been assessed and it is the Council's view that CIL IS PAYABLE on the development hereby approved as is detailed below. Full details about the CIL Charge including, amount and process for payment will be set out in the Regulation 65 Liability Notice which will be sent to you as soon as possible after this decision notice has been issued. If the development hereby approved is for a self-build dwelling, residential extension or residential annex you may be able to apply for relief from CIL. Further details about CIL are available on the Council's website or from the Planning Portal: www.planningportal.gov.uk/planning/applications/howtoapply/whattosubmit/cil

**APPLICATION NO. 2022/0819 - RECREATION GROUND,
MUIRFIELD ROAD, BESTWOOD**

Install a 6m column together with a 2m antennae extension and concrete base for a CCTV camera.

RESOLVED:

To Grant Conditional Planning Permission subject to the following conditions:

Conditions

- 1 The development hereby permitted shall commence before the expiration of 3 years from the date of this permission.
- 2 This permission shall be carried out in accordance with the details set out in the application form, Site Location Plan, and Technical Specification; received by the Local Planning Authority on 18 August 2022.

Reasons

- 1 In order to comply with Section 51 of the Planning and Compulsory Purchase Act 2004.
- 2 For the avoidance of doubt.

Reasons for Decision

The proposed development is consistent with Gedling Borough planning policies. The proposal represents an acceptable form of development which seeks to reduce crime, the detection of crime and the fear of crime. The proposal is not considered to have an unacceptable impact on the visual amenity of the area. The proposal will not have an unacceptable impact on the residential amenity of the occupiers of neighbouring properties. It is considered that the proposal is appropriate for its context and is in accordance with the NPPF (Section 8 and 12), Policy 10 of the GBCAS (2014) and Policy 32 of the LPD.

Notes to Applicant

The Borough Council has worked positively and proactively with the applicant in accordance with paragraph 38 of the National Planning Policy Framework. During the processing of the application there were

no problems for which the Local Planning Authority had to seek a solution in relation to this application.

The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to The Coal Authority on 0845 762 6848. Further information is also available on The Coal Authority website at www.coal.decc.gov.uk. Property specific summary information on past, current and future coal mining activity can be obtained from The Coal Authority's Property Search Service on 0845 762 6848 or at www.groundstability.com

The applicant is advised that all planning permissions granted on or after 16th October 2015 may be subject to the Community Infrastructure Levy (CIL). Full details of CIL are available on the Council's website. The proposed development has been assessed and it is the Council's view that CIL is not payable on the development hereby approved as the development type proposed is zero rated in this location.

29 APPEAL DECISION REF: APP/N3020/C/21/3275688 & APP/N3020/C/21/3275690 - LAND TO THE WEST OF 175 MANSFIELD ROAD, PAPPLEWICK

The construction of unauthorised buildings, security cameras and lighting columns, front boundary walls with lanterns and gates, the erection of two ornamental statues, the material change of use of the land to a mixed used for the storage of vehicles, trailers and vehicle parts and the repairing of motor vehicles, also for the disposal of items by burning and the change of use of part of the access road to a landscaped grassed area and for the siting of two ornamental statues.

The Head of Development and Place introduced the report.

RESOLVED:

To note the information.

30 APPEAL DECISION REF: APP/N3020/W/22/3290775 - LAND PREVIOUSLY WARREN HILL COMMUNITY CHURCH

Erection of 6 two storey dwellings.

RESOLVED:

To note the information.

31 APPEAL DECISION REF: APP/N3020/W/22/3293642 - THE WRINKLY LETTUCE CAFE & BISTRO, 16 MAIN ROAD, GEDLING

Installation of decking.

RESOLVED:

To note the information.

32 APPEAL DECISION REF: APP/N3020/D/21/3286329 - 27 LONGDALE LANE, RAVENSHEAD

Detached garage.

RESOLVED:

To note the information.

33 FUTURE PLANNING APPLICATIONS

RESOLVED:

To note the information.

34 PLANNING DELEGATION PANEL ACTION SHEETS

RESOLVED:

To note the information.

35 ANY OTHER ITEMS WHICH THE CHAIR CONSIDERS URGENT.

None.

The meeting finished at 7.05 pm

Signed by Chair:
Date: